



# Water Quality Sampling Results Certificate

<b>Client: Healing Waters Project</b>	Certificate Ref:	TSBN1369496-1
River Lark, Mildenhall Jubilee Fields	Report Date:	31/05/2021
	Analysis Start Date:	28/05/2021

## Sampling Results

Healing Waters 1			
	Results	EC Bathing Water Directive (76/160/EEC)	EC Bathing Water Directive (2006/7/EC) (for inland waters)
Total coliforms (no/100 ml)	970	Pass Mandatory	-
E. coli (no/100 ml)	460	Pass Mandatory	Pass Excellent
Enterococci (no/100ml)	29	-	Pass Excellent

Healing Waters 2			
	Results	EC Bathing Water Directive (76/160/EEC)	EC Bathing Water Directive (2006/7/EC) (for inland waters)
Total coliforms (no/100 ml)	930	Pass Mandatory	-
E. coli (no/100 ml)	140	Pass Mandatory	Pass Excellent
Enterococci (no/100ml)	38	-	Pass Excellent

The testing results in this certificate relate only to the samples described above.

Unless otherwise stated, all results are expressed on an as received basis.

All analysis was carried out in UKAS accredited laboratory.