



Water Quality Sampling
Results Certificate

Client: Healing Waters Project	Certificate Ref:	TSBN1404881-1
Thetford Riverside, River Thet	Report Date:	13/08/2021
	Analysis Start Date:	10/08/2021

Sampling Results

Healing Waters 1			
	Results	EC Bathing Water Directive (76/160/EEC)	EC Bathing Water Directive (2006/7/EC) (for inland waters)
Total coliforms (no/100 ml)	59	Pass Guideline	-
E. coli (no/100 ml)	40	Pass Guideline	Pass Excellent
Enterococci (no/100ml)	26	-	Pass Excellent

Healing Waters 2			
	Results	EC Bathing Water Directive (76/160/EEC)	EC Bathing Water Directive (2006/7/EC) (for inland waters)
Total coliforms (no/100 ml)	230	Pass Guideline	-
E. coli (no/100 ml)	64	Pass Guideline	Pass Excellent
Enterococci (no/100ml)	40	-	Pass Excellent

The testing results in this certificate relate only to the samples described above.

Unless otherwise stated, all results are expressed on an as received basis.

All analysis was carried out in UKAS accredited laboratory.